



FINAL

Investigation of Indoor Air Quality

Kingston Secondary School
145 Kirkpatrick Street, Kingston, Ontario

Prepared for:

**Limestone District School
Board**

220 Portsmouth Avenue
Kingston, ON K7M 0G2

December 16, 2024

Pinchin File: 201262.340



Issued to: Limestone District School Board
Issued on: December 16, 2024
Pinchin File: 201262.340
Issuing Office: Kingston, ON
Primary Pinchin Contact: Sarah Young
613.541.1013
syoung@pinchin.com

Author: _____
Chris Wright
Senior Project Technologist

Reviewer: _____
Sarah Young, C.Tech.
Senior Technical Manager



TABLE OF CONTENTS

1.0	INTRODUCTION AND SCOPE	1
1.1	Statement of Understanding	1
1.2	Scope of Work	1
2.0	METHODOLOGY	1
2.1	Interview and Site Review	1
2.2	Test Methods and Criteria	1
3.0	FINDINGS	2
3.1	Results of Interviews	2
3.2	Facility Description.....	3
3.3	Results of Indoor Air Quality Tests	3
4.0	DISCUSSION	4
5.0	RECOMMENDATIONS.....	4
6.0	TERMS AND LIMITATIONS	4



APPENDICES

APPENDIX I	Drawings
APPENDIX II	Results of Direct-Reading Indoor Air Quality Measurements
APPENDIX III	Results of Data-Logging Indoor Air Quality Measurements

LIST OF TABLES

Table I – Parameters Tested, Recommended Limits and Instruments or Methods Used	2
Table II – Facility Description	3
Table III – Summary of IAQ Spot Measurements	3
Table IV – Summary of IAQ Data Logging Measurements.....	3



1.0 INTRODUCTION AND SCOPE

1.1 Statement of Understanding

Pinchin Ltd. (Pinchin) was retained by Limestone District School Board (Client) to complete an investigation of indoor air quality (IAQ) at 145 Kirkpatrick Street, Kingston, Ontario. The investigation was performed in response to occupant concerns regarding carbon dioxide in the building.

1.2 Scope of Work

Pinchin performed the initial round of spot measurements and deployed three data logging monitors on November 21, 2024. Pinchin returned to the Site on November 29, 2024 to retrieve the data logging monitors and performed additional rounds of spot measurements throughout the building.

The investigation involved the following activities:

- A review of reported concerns.
- Walkthrough site reviews for factors that could degrade air quality.
- Spot measurements of carbon dioxide (CO₂)
- Data-logging of CO₂ in the following area(s):
 - Room 154
 - Room 212
 - Room 302

2.0 METHODOLOGY

2.1 Interview and Site Review

Pinchin interviewed building staff, occupants, health and safety representatives, and managers to discuss the history of the building, maintenance practices, and any indoor air quality complaints.

The investigator reviewed conditions within the subject area(s) for factors that could degrade air quality.

All fieldwork was completed using industry-accepted best practice and following Pinchin Standard Operating Procedures.

2.2 Test Methods and Criteria

The following table presents a summary of the parameters measured in this investigation, the instruments and sampling methods used, the applicable units of measurement, and the criteria selected by Pinchin for the evaluation of the results.

All direct-reading instruments were calibrated before use or in accordance with manufacturers instructions.

Table I – Parameters Tested, Recommended Limits and Instruments or Methods Used

Parameter	Unit of Measurement	Recommended Limit	Instrumentation
CO ₂	Parts per million in air (ppm)	Outdoor Air ppm + 700 ppm ¹	TSI® Q-Trak IAQ monitor

¹Pinchin compared the carbon dioxide measurement to the criteria outlined in the document entitled American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE): Ventilation for Acceptable Indoor Air Quality [ANSI/ASHRAE Standard 62.1-2016]. Atlanta, GA: ASHRAE, 2016.

Typical outdoor CO₂ levels range between 300 and 500 ppm. Indoor carbon dioxide concentrations consistently above 800-1,000 ppm can result in occupants experiencing symptoms such as itchy or sore eyes, drowsiness, and/or mild headaches. Exposure to much higher levels of indoor carbon dioxide concentrations (i.e. >5,000 ppm) can cause dizziness, headaches, elevated blood pressure, and increased heart rate. For additional information, refer to the Environmental Abatement Council of Canada (EACC) Indoor Air Quality Guideline For Non-Industrial Workplaces.

3.0 FINDINGS

3.1 Results of Interviews

The Site Representatives reported the following:

- The building was constructed in 2018 and all HVAC, AHU's etc are original. Building staff perform routine filter changes every 3 months.
- Occupants of the building have raised general concerns regard carbon dioxide in the building.
- An HVAC contractor was retained in November 2024, to review the HVAC system and perform routine maintenance.
- Occupants have not reported any adverse health effects while in the building.

¹ American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE): Ventilation for Acceptable Indoor Air Quality [ANSI/ASHRAE Standard 62.1-2016]. Atlanta, GA: ASHRAE, 2016.



3.2 Facility Description

Below provides information as it relates to the area(s) assessed.

Table II – Facility Description

Item	Details
Construction Date	2018
Number of Floors	Three
Area Assessed	Approximately 60,000 square feet
HVAC	Boiler with hot water heating to radiators, indoor air handling unit
Flooring	Vinyl, wood, carpet and ceramic tiles
Interior Walls	Drywall and concrete block
Ceilings	Drywall and acoustic ceiling tiles

3.3 Results of Indoor Air Quality Tests

The results of IAQ spot measurements are provided in Appendix II. Appendix III presents the results of any data-logging of IAQ parameters. Appendix I presents the drawings.

Table III – Summary of IAQ Spot Measurements

Parameter	Concentration		Suggested Limit	Within Suggested Limit?
	Minimum	Maximum		
CO ₂ November 21, 2024	420 ppm	955 ppm	Outdoor Air ppm + 700 ppm	Yes
CO ₂ November 29, 2024	450 ppm	866 ppm	Outdoor Air ppm + 700 ppm	Yes

Pinchin deployed three monitors to data log the carbon dioxide in the building. The units were deployed from November 21 to November 29, 2024, with a log interval of one hour.

Table IV – Summary of IAQ Data Logging Measurements

Parameter	Concentration		Suggested Limit	Within Suggested Limit?
	Minimum	Maximum		
CO ₂ Monitor #19867, Room 154	432 ppm	967 ppm	Outdoor Air ppm + 700 ppm	Yes



Table IV – Summary of IAQ Data Logging Measurements

CO ₂ Monitor #13123, Room 212	413 ppm	923 ppm	Outdoor Air ppm + 700 ppm	Yes
CO ₂ Monitor #12492, Room 302*	568 ppm	700ppm	Outdoor Air ppm + 700 ppm	Yes

*Due to an equipment internal power malfunction of Monitor #12492 deployed in Room 302, only four measurements were datalogger between 12:11 a.m. and 3:08 a.m. on November 22, 2024. All measurements were within the acceptable criteria. Pinchin has not prepared a summary graph for this data.

4.0 DISCUSSION

All spot measurements of carbon dioxide collected on November 21, 2024 and November 29, 2024 along with the datalogging data collected in three locations were within the acceptable criteria. It is Pinchin’s understanding that the occupancy load of the building at the time of this investigation was typical to day to day use of the building with the exception of November 21-24, 2024. During November 21-24, 2024, occupancy load was higher than normal as a sporting event was hosted in the building.

Although one of the data logging monitors malfunctioned and limited data was collected, it is Pinchin’s opinion that the methodology and sample locations were representative of the building and the data did not report any elevated concentrations of carbon dioxide.

5.0 RECOMMENDATIONS

Pinchin offers the following recommendations to improve air quality within the assessed area(s):

1. Communicate the findings of this report to staff, members of the joint health and safety committee, tenants, and any other vested parties.
2. Continue to perform routine maintenance on HVAC to ensure adequate fresh air is introduced into the building.

6.0 TERMS AND LIMITATIONS

This work was performed subject to the Terms and Limitations presented or referenced in the proposal for this project.

Information provided by Pinchin is intended for Client use only. Pinchin will not provide results or information to any party unless disclosure by Pinchin is required by law. Any use by a third party of reports or documents authored by Pinchin or any reliance by a third party on or decisions made by a third party based on the findings described in said documents, is the sole responsibility of such third parties.



Investigation of Indoor Air Quality

Kingston Secondary School, 145 Kirkpatrick Street, Kingston, Ontario
Limestone District School Board


December 16, 2024
Pinchin File: 201262.340
FINAL

Pinchin accepts no responsibility for damages suffered by any third party as a result of decisions made or actions conducted. No other warranties are implied or expressed.




\\pinchin.com\kgn\Job\201000s\0201262.000 LIMESTONE,53VanOrderDr,KGN,DSR\0201262.340 LDSB,KSS,IEQ,Asmt\Deliverables\201262.340 IEQInvestigation KSS LDSB.docx

Template: Master Report Investigation of IAQ, IEQ, June 10, 2024

APPENDIX I
Drawings



LEGEND

-  DATA LOGGING LOCATION
-  SPOT MEASUREMENT
-  LDSB/ PINCHIN LOCATION

NOT ALL KNOWN OR SUSPECTED HAZARDOUS BUILDING MATERIALS MAY BE DEPICTED ON THE DRAWING. REFER TO THE HAZARDOUS BUILDING MATERIALS ASSESSMENT REPORT FOR A COMPLETE LIST OF KNOWN AND SUSPECTED HAZARDOUS BUILDING MATERIALS.

LEGEND IS COLOUR DEPENDENT. NON-COLOUR COPIES MAY ALTER INTERPRETATION.

BASE PLAN PROVIDED BY CLIENT.



PROJECT NAME:
INDOOR AIR QUALITY ASSESSMENT

CLIENT NAME:
LIMESTONE DISTRICT SCHOOL BOARD




PROJECT LOCATION:
**KINGSTON S.S.
145 KIRKPATRICK STREET
KINGSTON, ONTARIO**

FIGURE NAME:
FIRST FLOOR

PROJECT NUMBER: 201262.340	SCALE: NOT TO SCALE
DRAWN BY: CW	REVIEWED BY: SY
DATE: DECEMBER 2024	FIGURE NUMBER: 1 OF 3



LEGEND

-  DATA LOGGING LOCATION
-  SPOT MEASUREMENT
-  LDSB/ PINCHIN LOCATION

NOT ALL KNOWN OR SUSPECTED HAZARDOUS BUILDING MATERIALS MAY BE DEPICTED ON THE DRAWING. REFER TO THE HAZARDOUS BUILDING MATERIALS ASSESSMENT REPORT FOR A COMPLETE LIST OF KNOWN AND SUSPECTED HAZARDOUS BUILDING MATERIALS.

LEGEND IS COLOUR DEPENDENT. NON-COLOUR COPIES MAY ALTER INTERPRETATION.

BASE PLAN PROVIDED BY CLIENT.



PROJECT NAME:
INDOOR AIR QUALITY ASSESSMENT

CLIENT NAME:
LIMESTONE DISTRICT SCHOOL BOARD




PROJECT LOCATION:
**KINGSTON S.S.
145 KIRKPATRICK STREET
KINGSTON, ONTARIO**


FIGURE NAME:
SECOND FLOOR

PROJECT NUMBER: 201262.340	SCALE: NOT TO SCALE
DRAWN BY: CW	REVIEWED BY: SY
DATE: DECEMBER 2024	FIGURE NUMBER: 2 OF 3



LEGEND

-  DATA LOGGING LOCATION
-  SPOT MEASUREMENT
-  127 LDSB/ PINCHIN LOCATION



NOT ALL KNOWN OR SUSPECTED HAZARDOUS BUILDING MATERIALS MAY BE DEPICTED ON THE DRAWING. REFER TO THE HAZARDOUS BUILDING MATERIALS ASSESSMENT REPORT FOR A COMPLETE LIST OF KNOWN AND SUSPECTED HAZARDOUS BUILDING MATERIALS.

LEGEND IS COLOUR DEPENDENT. NON-COLOUR COPIES MAY ALTER INTERPRETATION.

BASE PLAN PROVIDED BY CLIENT.



PROJECT NAME: INDOOR AIR QUALITY ASSESSMENT	
CLIENT NAME: LIMESTONE DISTRICT SCHOOL BOARD	
PROJECT LOCATION: KINGSTON S.S. 145 KIRKPATRICK STREET KINGSTON, ONTARIO	
FIGURE NAME: THIRD FLOOR	
PROJECT NUMBER: 201262.340	SCALE: NOT TO SCALE
DRAWN BY: CW	REVIEWED BY: SY
DATE: DECEMBER 2024	FIGURE NUMBER: 3 OF 3

APPENDIX II

Results of Direct-Reading Indoor Air Quality Measurements



Client Name: Limestone District School Board
Site Address: 145 Kirkpatrick Street, Kingston, ON
Pinchin File: 201262.340
Date 2024-11-21
Date 2024-11-29

Occupancy Density Definitions

Vacant The room/area was not occupied at the time of the measurement.

Design The occupancy of the room/area matched the designed intention of the room /area

Low The occupancy of the room/area was below the designed intention of the room /area

High The occupancy of the room/area was above the designed intention of the room /area

Location No: 0		Location Name: Outdoor		
	Time	Occupant Density		CO2 (ppm)
	11/21 08:20 AM	Low		492
	11/21 10:36 AM	Vacant		431
	11/21 11:54 AM	Vacant		454
	11/21 02:13 PM	Vacant		440
	11/21 03:46 PM	Vacant		431
	11/29 08:11 AM	Low		490
	11/29 09:47 AM	Vacant		454
	11/29 11:20 AM	Vacant		466
Notes:	Raining			
	Nov 21 Average			450
	Nov 29 Average			470

Location No: 1		Location Name: Gym		
	Time	Occupant Density		CO2 (ppm)
	11/21 09:05 AM	Design		779
	11/21 12:05 PM	Design		810
	11/21 02:18 PM	High		842
	11/29 08:24 AM	Low		491
	11/29 10:01 AM	Low		657



Location No: 2	Location Name: Gym		
	Time	Occupant Density	CO2 (ppm)
	11/21 09:08 AM	High	926
	11/21 12:02 PM	Design	818
	11/21 02:16 PM	High	824
	11/29 08:19 AM	Low	456
	11/29 09:59 AM	Low	630

Location No: 100	Location Name: Admin Office		
	Time	Occupant Density	CO2 (ppm)
	11/21 08:26 AM	Design	860
	11/21 12:22 PM	Design	702
	11/21 02:35 PM	Design	689
	11/29 08:37 AM	Design	589
	11/29 10:16 AM	Design	574

Location No: 101	Location Name: Foyer		
	Time	Occupant Density	CO2 (ppm)
	11/21 08:35 AM	Design	751
	11/21 12:07 PM	Design	816
	11/21 02:19 PM	Low	743
	11/29 08:36 AM	Low	610
	11/29 10:02 AM	Low	618

Location No: 107	Location Name: Meeting Room		
	Time	Occupant Density	CO2 (ppm)
	11/21 08:28 AM	Low	630
	11/21 12:23 PM	Vacant	504
	11/21 02:37 PM	Low	519
	11/29 08:39 AM	Low	485
	11/29 10:17 AM	Vacant	472



Location No: 114	Location Name: Library		
	Time	Occupant Density	CO2 (ppm)
	11/21 08:30 AM	Low	545
	11/21 12:25 PM	Low	703
	11/21 02:39 PM	Low	689
	11/29 08:40 AM	Low	500

Location No: 124	Location Name: Theater Arts		
	Time	Occupant Density	CO2 (ppm)
	11/21 08:32 AM	Vacant	560
	11/21 12:27 PM	Low	614
	11/21 02:41 PM	Vacant	575
	11/29 08:41 AM	Low	450
	11/29 10:20 AM	Low	493

Location No: 125	Location Name: Music Room		
	Time	Occupant Density	CO2 (ppm)
	11/21 08:48 AM	Design	761
	11/21 12:29 PM	Low	955
	11/29 08:44 AM	Design	740

Location No: 126	Location Name: Music Room		
	Time	Occupant Density	CO2 (ppm)
	11/21 08:47 AM	Low	676
	11/21 12:31 PM	Low	721
	11/21 02:45 PM	Low	720
	11/29 08:46 AM	Design	604
	11/29 10:18 AM	Design	661



Location No: 130	Location Name: Cafeteria		
	Time	Occupant Density	CO2 (ppm)
	11/21 08:41 AM	Vacant	540
	11/21 12:33 PM	Low	718
	11/21 02:48 PM	Low	614
	11/29 08:49 AM	Low	519
	11/29 10:23 AM	Low	501

Location No: 132	Location Name: Culinary		
	Time	Occupant Density	CO2 (ppm)
	11/21 08:45 AM	Design	641
	11/21 12:32 PM	Design	847
	11/29 08:48 AM	Design	597
	11/29 10:22 AM	Design	562

Location No: 141	Location Name: Classroom		
	Time	Occupant Density	CO2 (ppm)
	11/21 12:04 PM	Low	584
	11/29 08:20 AM	Low	478
	11/29 10:00 AM	Design	593

Location No: 142	Location Name: Classroom		
	Time	Occupant Density	CO2 (ppm)
	11/21 09:10 AM	Low	651
	11/21 12:01 PM	Low	672
	11/21 02:15 PM	Low	711



Location No: 143	Location Name: Technology Classroom		
	Time	Occupant Density	CO2 (ppm)
	11/21 09:13 AM	Design	611
	11/21 12:00 PM	Vacant	585
	11/21 02:10 PM	Low	672
	11/29 08:18 AM	Low	477
	11/29 09:58 AM	Design	630

Location No: 144	Location Name: Technology Classroom		
	Time	Occupant Density	CO2 (ppm)
	11/21 09:14 AM	Design	755
	11/21 11:59 AM	Design	719
	11/21 02:10 PM	Design	733
	11/29 09:56 AM	Design	642

Location No: 145	Location Name: Technology Classroom		
	Time	Occupant Density	CO2 (ppm)
	11/21 09:17 AM	Vacant	673
	11/21 11:58 AM	Design	758
	11/21 02:09 PM	Low	688
	11/29 09:55 AM	Low	588

Location No: 147	Location Name: Custodian		
	Time	Occupant Density	CO2 (ppm)
	11/21 09:19 AM	Design	825
	11/21 11:57 AM	Design	741
	11/21 02:01 PM	Design	761
	11/29 08:15 AM	Low	537
	11/29 09:54 AM	Vacant	576



Location No: 152	Location Name: Classroom		
	Time	Occupant Density	CO2 (ppm)
	11/21 09:01 AM	Design	681
	11/21 12:20 PM	Low	548
	11/21 02:32 PM	Low	533
	11/29 08:34 AM	Low	523
	11/29 10:14 AM	Low	515

Location No: 153	Location Name: Classroom		
	Time	Occupant Density	CO2 (ppm)
	11/21 08:59 AM	Design	855
	11/21 12:16 PM	Vacant	529
	11/21 02:29 PM	Vacant	594
	11/29 08:31 AM	Design	714

Location No: 154	Location Name: Classroom		
	Time	Occupant Density	CO2 (ppm)
	11/21 08:58 AM	Vacant	633
	11/21 12:11 PM	Design	802
	11/21 02:26 PM	Low	765
	11/29 08:26 AM	Design	612
	11/29 10:06 AM	Design	846

Data Logging: Q-TRAK19867

Location No: 156	Location Name: Classroom		
	Time	Occupant Density	CO2 (ppm)
	11/21 08:56 AM	Low	639
	11/21 12:10 PM	Low	596
	11/21 02:25 PM	Low	662
	11/29 08:27 AM	Low	575
	11/29 10:04 AM	Low	662



Location No: 157	Location Name: Classroom		
	Time	Occupant Density	CO2 (ppm)
	11/21 08:55 AM	Design	844
	11/21 12:09 PM	Design	762
	11/21 02:21 PM	Design	853
	11/29 10:05 AM	Design	795

Location No: 158	Location Name: Classroom		
	Time	Occupant Density	CO2 (ppm)
	11/21 08:53 AM	Low	766
	11/21 12:12 PM	Design	830
	11/29 08:29 AM	Design	568

Location No: 160	Location Name: Classroom		
	Time	Occupant Density	CO2 (ppm)
	11/21 09:00 AM	Low	626
	11/21 12:15 PM	Design	630
	11/21 02:30 PM	Low	615
	11/29 08:32 AM	Low	574
	11/29 10:13 AM	Vacant	524

Location No: 161	Location Name: Students Services		
	Time	Occupant Density	CO2 (ppm)
	11/21 08:50 AM	Design	741
	11/21 12:19 PM	Design	605
	11/21 02:33 PM	Design	654
	11/29 08:35 AM	Low	564
	11/29 10:15 AM	Design	543



Location No: 201	Location Name: Classroom		
	Time	Occupant Density	CO2 (ppm)
	11/21 09:23 AM	Vacant	549
	11/21 12:50 PM	Design	858
	11/21 02:51 PM	Vacant	561
	11/29 09:02 AM	Low	583
	11/29 10:39 AM	Design	726

Location No: 202	Location Name: Classroom		
	Time	Occupant Density	CO2 (ppm)
	11/21 09:25 AM	Design	809
	11/21 12:49 PM	Low	570
	11/29 09:01 AM	Design	655

Location No: 203	Location Name: Classroom		
	Time	Occupant Density	CO2 (ppm)
	11/29 10:37 AM	Vacant	551

Location No: 204	Location Name: Classroom		
	Time	Occupant Density	CO2 (ppm)
	11/21 09:26 AM	Low	542
	11/21 12:46 PM	Vacant	576
	11/21 02:57 PM	Low	521
	11/29 08:59 AM	Low	561

Location No: 205	Location Name: Classroom		
	Time	Occupant Density	CO2 (ppm)
	11/21 09:27 AM	Design	707
	11/21 12:44 PM	Vacant	566
	11/21 02:55 PM	Vacant	565
	11/29 08:57 AM	Design	707



Location No: 206	Location Name: Classroom		
	Time	Occupant Density	CO2 (ppm)
	11/21 09:28 AM	Design	706
	11/21 12:42 PM	Low	576
	11/21 02:52 PM	Vacant	581
	11/29 08:54 AM	Low	540

Location No: 207	Location Name: Classroom		
	Time	Occupant Density	CO2 (ppm)
	11/21 09:30 AM	Design	707
	11/21 12:39 PM	Design	670
	11/29 08:53 AM	Low	621
	11/29 10:30 AM	Design	840

Location No: 212	Location Name: Classroom		
	Time	Occupant Density	CO2 (ppm)
	11/21 09:31 AM	Design	766
	11/21 12:43 PM	Vacant	616
	11/21 02:54 PM	Vacant	564
	11/29 08:55 AM	Design	656
	11/29 10:32 AM	Design	727

Data Logging: Q-Trak13123

Location No: 213	Location Name: Classroom		
	Time	Occupant Density	CO2 (ppm)
	11/21 09:33 AM	Vacant	599
	11/21 12:46 PM	Design	618
	11/21 02:56 PM	Vacant	554
	11/29 08:58 AM	Design	696
	11/29 10:36 AM	Low	583



Location No: 214	Location Name: Student Support Classroom		
	Time	Occupant Density	CO2 (ppm)
	11/21 09:35 AM	Low	647
	11/21 12:48 PM	Low	640
	11/21 02:58 PM	Vacant	531
	11/29 09:00 AM	Low	587
	11/29 10:38 AM	Low	574

Location No: 216	Location Name: Staff Work Room		
	Time	Occupant Density	CO2 (ppm)
	11/21 09:37 AM	Low	555
	11/21 12:52 PM	Low	649
	11/21 03:02 PM	Vacant	517
	11/29 09:13 AM	Low	593

Location No: 220	Location Name: Classroom		
	Time	Occupant Density	CO2 (ppm)
	11/21 09:39 AM	Low	566
	11/21 01:01 PM	Design	785
	11/21 03:12 PM	Vacant	479

Location No: 221	Location Name: Classroom		
	Time	Occupant Density	CO2 (ppm)
	11/21 09:40 AM	Design	765
	11/21 12:58 PM	Design	696
	11/21 03:09 PM	Vacant	463
	11/29 09:09 AM	Design	728
	11/29 10:43 AM	Design	647



Location No: 222	Location Name: Classroom		
	Time	Occupant Density	CO2 (ppm)
	11/21 09:42 AM	Low	903
	11/21 12:56 PM	Design	757
	11/29 09:06 AM	Design	693

Location No: 224	Location Name: Classroom		
	Time	Occupant Density	CO2 (ppm)
	11/21 09:44 AM	Low	569
	11/21 12:53 PM	Low	533
	11/21 03:04 PM	Low	430
	11/29 09:05 AM	Design	613
	11/29 10:41 AM	Design	565

Location No: 225	Location Name: Classroom		
	Time	Occupant Density	CO2 (ppm)
	11/21 09:46 AM	Vacant	599
	11/21 12:55 PM	Low	564
	11/21 03:06 PM	Vacant	428
	11/29 09:04 AM	Design	619

Location No: 226	Location Name: Classroom		
	Time	Occupant Density	CO2 (ppm)
	11/21 09:45 AM	Low	554
	11/21 12:57 PM	Low	578
	11/21 03:08 PM	Vacant	425
	11/29 09:08 AM	Design	669
	11/29 10:42 AM	Design	586



Location No: 227	Location Name: Classroom		
	Time	Occupant Density	CO2 (ppm)
	11/21 09:48 AM	Low	725
	11/21 01:00 PM	Design	621
	11/21 03:11 PM	Low	464
	11/29 09:10 AM	Design	691
	11/29 10:44 AM	Design	617

Location No: 228	Location Name: Photography Classroom		
	Time	Occupant Density	CO2 (ppm)
	11/21 09:50 AM	Design	807
	11/21 01:02 PM	Design	731
	11/29 09:14 AM	Design	668
	11/29 10:45 AM	Design	672

Location No: 229	Location Name: Visual Art Classroom		
	Time	Occupant Density	CO2 (ppm)
	11/21 09:51 AM	Design	657
	11/21 01:03 PM	Design	677
	11/21 03:14 PM	Vacant	436
	11/29 09:15 AM	Design	650

Location No: 230	Location Name: Visual Arts Classroom		
	Time	Occupant Density	CO2 (ppm)
	11/21 09:53 AM	Low	632
	11/21 01:06 PM	Low	606
	11/21 03:15 PM	Vacant	484
	11/29 09:16 AM	Low	602
	11/29 10:47 AM	Low	541



Location No: 232	Location Name: Exercise Room		
	Time	Occupant Density	CO2 (ppm)
	11/21 09:57 AM	Vacant	473
	11/21 01:09 PM	Low	541
	11/21 03:18 PM	Vacant	454
	11/29 09:18 AM	Low	580
	11/29 10:50 AM	Low	559

Location No: 233	Location Name: Classroom		
	Time	Occupant Density	CO2 (ppm)
	11/21 01:10 PM	Low	773
	11/21 03:19 PM	Vacant	470
	11/29 10:52 AM	Vacant	488

Location No: 234	Location Name: Radio Booth		
	Time	Occupant Density	CO2 (ppm)
	11/21 09:54 AM	Design	833
	11/21 01:07 PM	Vacant	595
	11/21 03:17 PM	Vacant	515
	11/29 09:17 AM	Vacant	650

Location No: 301	Location Name: Classroom		
	Time	Occupant Density	CO2 (ppm)
	11/21 10:31 AM	Design	785
	11/21 01:43 PM	Low	624
	11/21 03:31 PM	Low	550
	11/29 09:34 AM	Low	610



Location No: 302	Location Name: Classroom		
	Time	Occupant Density	CO2 (ppm)
	11/21 10:30 AM	Low	561
	11/21 01:24 PM	Design	842
	11/21 03:30 PM	Vacant	473
	11/29 09:31 AM	Low	625
	11/29 11:02 AM	Vacant	525

Data Logging: Q-Trak12492

Location No: 303	Location Name: Classroom		
	Time	Occupant Density	CO2 (ppm)
	11/21 10:28 AM	Design	455
	11/21 01:22 PM	Low	758
	11/29 09:30 AM	Design	741

Location No: 304	Location Name: Classroom		
	Time	Occupant Density	CO2 (ppm)
	11/21 10:27 AM	Design	784
	11/21 01:19 PM	Design	939
	11/21 03:29 PM	Vacant	468
	11/29 09:29 AM	Design	688
	11/29 10:58 AM	Design	698

Location No: 305	Location Name: Classroom		
	Time	Occupant Density	CO2 (ppm)
	11/21 10:26 AM	Design	873
	11/21 01:18 PM	Design	928
	11/21 03:25 PM	Vacant	466
	11/29 09:27 AM	Design	775
	11/29 10:56 AM	Design	749



Location No: 306	Location Name: Classroom		
	Time	Occupant Density	CO2 (ppm)
	11/21 10:25 AM	Design	706
	11/21 01:16 PM	Low	753
	11/21 03:27 PM	Vacant	466
	11/29 09:24 AM	Design	694

Location No: 307	Location Name: Classroom		
	Time	Occupant Density	CO2 (ppm)
	11/21 10:24 AM	Design	687
	11/21 01:45 PM	Low	748
	11/21 03:22 PM	Vacant	471
	11/29 09:22 AM	Design	720

Location No: 308	Location Name: Classroom		
	Time	Occupant Density	CO2 (ppm)
	11/21 10:23 AM	Design	719
	11/21 01:15 PM	Design	884
	11/29 09:23 AM	Design	680
	11/29 10:55 AM	Design	678

Location No: 309	Location Name: Classroom		
	Time	Occupant Density	CO2 (ppm)
	11/21 10:22 AM	Design	659
	11/21 01:17 PM	Low	780
	11/21 03:23 PM	Vacant	466
	11/29 09:25 AM	Low	688



Location No: 310	Location Name: Classroom		
	Time	Occupant Density	CO2 (ppm)
	11/21 10:21 AM	Design	712
	11/21 01:21 PM	Low	894
	11/21 03:28 PM	Vacant	464
	11/29 09:28 AM	Design	690
	11/29 10:57 AM	Low	670

Location No: 311	Location Name: Classroom		
	Time	Occupant Density	CO2 (ppm)
	11/21 10:20 AM	Design	682
	11/21 01:23 PM	Design	867
	11/29 10:59 AM	Design	702

Location No: 312	Location Name: Classroom		
	Time	Occupant Density	CO2 (ppm)
	11/21 10:19 AM	Vacant	585
	11/21 01:26 PM	Low	688
	11/21 03:30 PM	Vacant	440
	11/29 09:33 AM	Low	652
	11/29 11:01 AM	Low	567

Location No: 313	Location Name: Classroom		
	Time	Occupant Density	CO2 (ppm)
	11/21 10:17 AM	Design	765
	11/21 01:28 PM	Low	754
	11/21 03:32 PM	Vacant	493
	11/29 09:35 AM	Design	684



Location No: 318	Location Name: Classroom		
	Time	Occupant Density	CO2 (ppm)
	11/21 10:16 AM	Low	673
	11/21 01:40 PM	Low	711
	11/29 11:13 AM	Low	726

Location No: 319	Location Name: Classroom		
	Time	Occupant Density	CO2 (ppm)
	11/21 10:15 AM	Design	760
	11/21 01:37 PM	Low	710
	11/21 03:34 PM	Vacant	437
	11/29 09:37 AM	Design	715

Location No: 320	Location Name: Classroom		
	Time	Occupant Density	CO2 (ppm)
	11/21 10:14 AM	Design	786
	11/21 01:35 PM	Vacant	572
	11/21 03:37 PM	Low	490
	11/29 09:39 AM	Design	810
	11/29 11:14 AM	Vacant	698

Location No: 321	Location Name: Classroom		
	Time	Occupant Density	CO2 (ppm)
	11/21 10:12 AM	Design	760
	11/21 01:33 PM	Low	697
	11/21 03:40 PM	Vacant	421



Location No: 322	Location Name: Classroom		
	Time	Occupant Density	CO2 (ppm)
	11/21 10:11 AM	Design	671
	11/21 01:31 PM	Design	811
	11/21 03:07 PM	Vacant	477
	11/29 09:42 AM	Low	770

Location No: 323	Location Name: Classroom		
	Time	Occupant Density	CO2 (ppm)
	11/21 10:07 AM	Design	703
	11/21 01:30 PM	Low	838
	11/21 03:42 PM	Low	525
	11/29 11:17 AM	Vacant	685

Location No: 324	Location Name: Classroom		
	Time	Occupant Density	CO2 (ppm)
	11/21 10:09 AM	Vacant	571
	11/21 01:32 PM	Vacant	576
	11/21 03:41 PM	Vacant	420
	11/29 11:16 AM	Low	581

Location No: 325	Location Name: Classroom		
	Time	Occupant Density	CO2 (ppm)
	11/21 10:10 AM	Vacant	613
	11/21 01:34 PM	Vacant	572
	11/21 03:39 PM	Vacant	425
	11/29 09:41 AM	Low	866
	11/29 11:15 AM	Vacant	602



Location No: 326	Location Name: Special Education		
	Time	Occupant Density	CO2 (ppm)
	11/21 10:05 AM	Low	622
	11/21 01:36 PM	Design	657
	11/21 03:38 PM	Vacant	435

Location No: 327	Location Name: Classroom		
	Time	Occupant Density	CO2 (ppm)
	11/21 10:04 AM	Design	640
	11/21 01:38 PM	Low	596
	11/21 03:36 PM	Vacant	432
	11/29 09:38 AM	Design	591

Location No: 328	Location Name: Staff Lounge		
	Time	Occupant Density	CO2 (ppm)
	11/21 10:02 AM	Low	596
	11/21 01:41 PM	Low	613
	11/21 03:33 PM	Low	422
	11/29 09:36 AM	Low	554
	11/29 11:11 AM	Design	619

APPENDIX III

Results of Data-Logging Indoor Air Quality Measurements

